



COOKING AND OPEN FLAME FORM

Natural/LP Gas, Cooking, Open Flame, Heat Producing Device

Exhibiting Company

Booth Number

Booth Size

X

Agreement Contact Name

Email

Phone Number

Fax

Please complete and sign this form if you intend to conduct ANY of the following activities within your exhibit space. Cooking, open flame and gas appliances require Fire Marshal approval in advance. Introduction of a hazard deemed unsafe or out of the ordinary (i.e. grease-laden vapors, flammable liquids or gases), by the Orange County Fire Rescue Department may require a firewatch. Please consult the Orange County Convention Center (OCCC) website at www.occc.net/Exhibitor-Guidelines-Information for all OCCC and Orange County Fire Rescue's terms and conditions.

Additional Information

- A 2A:10BC fire extinguisher (5 lb. ABC) with a current tag from a licensed fire extinguisher contractor, must be in the exhibit booth for any gas appliances, cooking or open flame. The fire extinguisher must be located no more than thirty feet (30') from any cooking, open flame or heat producing appliance.
- For fryers with cooking oil, a Class K fire extinguisher with a current tag from a licensed fire extinguisher contractor must be in the exhibit booth. The extinguisher must be no more than ten feet (10') from the cooking appliance.
- If a fire extinguisher is necessary for your booth, you may rent one from OCCC Exhibitor Services.
- Provide a four-foot (4') space or barrier to separate the attendees or general public from a cooking, open flame or heat producing appliance.
- LP Gas (i.e. propane, butane) and Natural Gas may be ordered via Exhibitor Services only after approval from the Orange County Fire Marshal. The amount of LP Gas permitted in the building is limited to a nominal 5 lb. container.
- Please submit manufacturer specifications for larger equipment (ovens, deep fryers, etc.).
- Exhibitor to provide a list of menu/food items that will be cooked on/in the equipment.
- Please indicate, which appliance(s), if any, need to be left operating overnight.
- Please contact the Orange County Fire Marshal at **407-685-9811** with any questions.

